

# CERTIFICA (A) T

## Belg 26/148/27.14

CONFORM BEVEILIGDE TOESTELLEN - CONFORME BEVEILIGINGEN  
 APPAREILS CONFORMEMENT PROTÉGÉS - PROTECTIONS CONFORMES  
 VIV00882026


Toestel of beveiliging  
 Appareil ou protection  
 Appliance or protection

Merk / Marque  
 Brand

**Keukenmengkranen met filter, boiler, koeling en CO<sub>2</sub>-toevoeging**  
**Robinets de cuisine avec filtre, boiler, refroidissement et ajout de CO<sub>2</sub>**

**GROHE**

104416	Blue 2.0 C-Spout
104416?	Blue 2.0 C-Spout faucet
104421	Blue 2.0 L-Spout
104421?	Blue 2.0 L-Spout faucet
104424	Blue 2.0 C-Spout pull-out
104424?	Blue 2.0 C-Spout pull-out faucet
104430	Blue 2.0 L-Spout pull-out
104430?	Blue 2.0 L-Spout pull-out faucet
104432?	Blue Home 2.0 cooler EU
104433?	Blue Professional 2.0 Cooler EU
106317	Blue All in One L-Spout
106318	Blue All in One faucet C-Spout
106319	Blue All in One L-Spout Pull-Out
106350	Blue All in One C-Spout Pull-Out
106351	Blue All in One WCU
136663	Red L-Spout
136664	Red faucet C-Spout
136665	Red L-Spout Pull-Out
136666	Red C-Spout Pull-Out
136667	Red Boiler M-Size
136668	Red Boiler L-Size
Type 136669	Red Boiler M-Size
136670	Red Boiler L-Size
30382?	GROHE Blue Pure Minta
30383?	GROHE Blue Pure
30385?	GROHE Blue Pure
30387?	GROHE Blue Pure
30581?	GROHE Blue Pure
30584?	GROHE Blue Pure
30588?	GROHE Blue Pure
30590?	GROHE Blue Pure
31302?	GROHE Blue Pro
31323?	GROHE Blue Pro
31323?	GROHE Blue Professional
31324?	GROHE Blue Professional
31325?	GROHE Blue Pro
31326?	GROHE Blue Pro
31347?	GROHE Blue Pro
31454?	GROHE Blue Home
31455?	GROHE Blue Home
31456?	GROHE Blue Home
31498?	GROHE Blue Home
31539?	GROHE Blue Home



Belgaqua

	31541?	GROHE Blue Home
	40554?	GROHE Blue Pro
	40698?	GROHE Blue Pro
	40711?	GROHE Blue Home
	40764?	GROHE Blue Home
Goedgekeurd op / Approuvé le Approval date	16/04/2026	
Vervaldatum / Date d'expiration Expiry date	16/04/2031	
Opmerking / Remarque Remark	Conform mits voorplaatsing van een goedgekeurde beveiliging type EA op koudwateraansluiting voor boiler, koeling en CO <sub>2</sub> . Conforme moyennant le placement d'une protection agréée de type EA sur l'alimentation en eau froide pour le boiler, refroidissement et CO <sub>2</sub> .	
Bedrijf / Société Company	GROHE nv/sa	
Adres / Adresse Address	Leuvensesteenweg 369 1932 Zaventem	
Contact	Johan Ombelets	

Voor de Coördinatiegroep Waterinstallaties  
Pour le Groupe de Coordination Installations d'Eau  
On behalf of the Coordination Committee Water Installations

G. De Meulemeester,  
**Belgaqua**