



# CERTIFICATE

## SWEDISH TYPE APPROVAL 1531 WITH DECISION ON PRODUCTION CONTROL

**KEYWORD:** Sanitary Watertaps

**BBR 6:62**

**Holder: Grohe AG**

Industriepark Edelburg 58675 Hemer, Germany

Tel: +49 2372 93-1775

Webb: [www.grohe.com](http://www.grohe.com)

**Product name: Baulines Extension Bidet**

Single lever mixer in brass (EN 817). The mixers are fitted with type approved flexible connection hoses.

Product overview shown in the associated documents in the type approval, appendix 1

**Intended use**

Single lever mixer for hot and cold tap water

**Approval**

Products made and installed according to related documents are approved with respect to the following sections of the Swedish Building Regulations (BBR):

Tap water installations– 2 <sup>nd</sup> paragraph	6:62*
Tap water flow	6:623
Design – 1 <sup>st</sup> paragraph	6:625

\*The products meet the requirements of the BFS 2014: 3

For the intended use the products meets the following requirements of PBL, regulations governing the technical properties of materials, products etc. used in construction works Chapter 8 Section 4 about the technical characteristics of buildings and constructions.

**3. Protection with regard to hygiene, health and environment**

Appendix 1: Associated documents	15.08.2018
Appendix 2: Product marking	15.08.2018
Appendix 3: Control	15.08.2018
Appendix 4: Basis for approval	15.08.2018

**Kiwa Sverige AB**  
Campus Gräsvik 1  
SE-371 75 Karlskrona

Tel +46 (0)455-30 56 00  
Fax +46 (0)455-104 36  
[bygg@kiwa.se](mailto:bygg@kiwa.se)  
[www.kiwa.se](http://www.kiwa.se)



Accred. no. 1913  
Certification of  
Products  
ISO/IEC 17065

Date of decision: 15.08.2018

Ref. no: 673/18

Valid until: 14.08.2023

**Kiwa Sverige AB**

Magnus Jerlmark  
Technical manager

Johnny Ostfeldt  
Project leader

**Annex 1**

**Type Approval No. 1531**

**Product: Baulines Extension Bidet**

**Holder: GROHE AG**

**ASSOCIATED DOCUMENTS 15/08/2018**

**Baulines Extension – Approved list of products**

Art. no.	Description	Install. instruction
23754000	Bau Flow bidet mixer plastic waste set	t990706031
23766000	Start Curve bidet mixer plastic waste set	t990711031
23770000	Start Flow bidet mixer plastic waste set	t990703031
23785000	Start Classic bidet plastic waste set	t990718031

**Annex 2**



**Type Approval No. 1531**

**Product: Baulines Extension Bidet**

**Holder: Grohe AG**

**PRODUCT MARKING 15/08/2018**

The product shall be permanently labelled with the following information:

- a. Holder: Grohe AG
- b. Product name: Baulines Extension Bidet
- c. Manufacturing site: Acc. code
- d. Traceable mark to production date.
- e. Information on class or other important information
- f. Kiwa Sverige  Type Approval no: 1531 and the reg. mark of Boverket: 
- g. Ackrediteringsnummer: 1913
- h. Designated Inspection Body: KIWA

Manufacturer's declaration according to § 17 of the Type 7 in the accompanying documents:

Manufacturer's declaration: *The manufacture of this product has been made in accordance with the Construction Products Certificate decision on production control and the documents submitted to the decision of issue of this certificate.*



**Annex 3****Type Approval No. 1531****Product: Baulines Extension Bidet****Holder: GROHE AG****CONTROL 15/08/2018****Instructions for control**

Production Control must be carried out in accordance with instructions for control dated 02/06/16 According to inspection agreement no. 148/15, between Grohe AG and Kiwa.

**Annual reporting:**

The validity of the Type Approval requires that the production control is carried out and that the manufacturer annually fulfils the requirements for supervisory control. Annual supervisory control shall be conducted by the inspection body Kiwa.

**TBuilding Control:**

Building Control must be carried out through identifying the products, and control of the correct installation of the product by an expert, according to the manual.

**Annex 4****Type Approval No. 1531****Product: Baulines Extension Bidet****Holder: Grohe AG****BASIS FOR APPROVAL 15/08/2018**

The Type Approval is based on:

Baulines test reports 357- 367/ 2017 Fraunhofer IBP EN ISO 3822, (Sound)

DANAK (DTI) Migration report 762582-1, 2, 3, 4, 5, 6

Kiwa Examination Report 170601382/002-001 (EN 817\_2) /002 (EN 817)

BOM & drawing in KIWA's files

Control agreement no. 148/15 dated 2016-06-02.

Evaluation report case no. 673-18 dated 15/08/2018

