



Certificate number: 2204730 (1)

Issued 19/04/2022

Expires 19/04/2027

Kiwa Regulation 4 (KUKreg4) Certification

Evaluation Guideline – Kiwa UK – EG004 – Regulation 4(1)(a)

Model number(s) – see Appendix

Grohe AG.

Kiwa Watertec declares that legitimate confidence exists in the products specified in this certificate and supplied by the above organisation be relied upon to comply with the Kiwa Evaluation Guideline referred above.

Which verifies the requirements of:

Regulation 4(1)a of the Water Supply (Water Fittings) Regulations 1999 England & Wales: 2009 Northern Ireland and 2014 Byelaws Scotland.

This certificate has been issued in accordance with the Kiwa regulations for product certification.

Signed on behalf of Kiwa Watertec

David Jay, Business Unit Manager – Authorised Signatory
Kiwa Watertec

Publication of this certificate is allowed.

Products are intended to be used in the UK only. For other countries, other (National) requirements will apply.

See <https://www.kiwa.com/gb/en/about-kiwa/water-products/> to ensure that the certificate is still valid.

Kiwa Watertec
(A Trading Division of Kiwa Ltd)
26A Rassau Industrial Estate
Ebbw Vale
Gwent
NP23 5SD
United Kingdom
T +44 (0)1495 308185
uk.water@kiwa.com
www.kiwa.co.uk

Certificate Issued to:
Grohe AG
Industreipark Edelburg
58675 Hemer
Germany



Product Certificate

Appendix to Certificate number: 2204730

The following products belong to this certificate

PRODUCT DESCRIPTION Grohe Eurodisc Cosmopolitan sink mixer with a swivel spout and ceramic cartridge headwork. ATS3 – Without Production Surveillance.
MODEL(S) 33.770.002.
SIZE: Stainless steel braided PEX lined flexible hose assemblies with 3/8" captive nut end connections.
SCOPE: Manufacturer recommended maximum working pressure 10 Bar & maximum operating temperature 60°C. Hygienic Purposes: Non-metallic materials suitable for continuous use up to 60°C.
MARKING Design & Engineering Germany, date of manufacture, Made in Portugal on body. 'Grohe' logo on operating member.
MATERIALS Non-metallic materials assessed (BS6920) to point of discharge.
BACKFLOW PROTECTION NOTES Consider balanced supplies or appropriate backflow protection at the inlets. If this tap or combination tap is installed so that its base is no lower than the spillover level of the receiving vessel a Type AUK3 air gap is achieved.
ADDITIONAL NOTES Opacity cannot be guaranteed at inlet hoses.

Extra Notes