



Certificate number: 2304747 (1)

Issued 24/04/2023

Expires 24/04/2028

Kiwa Regulation 4 (KUKreg4) Certification

Evaluation Guideline – Kiwa UK – EG004 – Regulation 4(1)(a)

Model number(s) – see Appendix

Grohe AG.

Kiwa Watertec declares that legitimate confidence exists in the products specified in this certificate and supplied by the above organisation be relied upon to comply with the Kiwa Evaluation Guideline referred above.

Which verifies the requirements of:

Regulation 4(1)a of the Water Supply (Water Fittings) Regulations 1999 England & Wales: 2009 Northern Ireland and 2014 Byelaws Scotland.

This certificate has been issued in accordance with the Kiwa regulations for product certification.

Signed on behalf of Kiwa Watertec

David Jay, Business Unit Manager – Authorised Signatory
Kiwa Watertec

Publication of this certificate is allowed.

Products are intended to be used in the UK only. For other countries, other (National) requirements will apply.

See <https://www.kiwa.com/gb/en/about-kiwa/water-products/> or the QR code below to ensure that the certificate is still valid.

Kiwa Watertec
(A Trading Division of Kiwa Ltd)
26A Rassau Industrial Estate
Ebbw Vale
Gwent
NP23 5SD
United Kingdom
T +44 (0)1495 308185
uk.water@kiwa.com
www.kiwa.co.uk

Certificate Issued to:
Grohe AG
Industriepark Edelburg
58675 Hemer
Germany



KUKreg4

Product Certificate

Appendix to Certificate number: 2304747

The following products belong to this certificate

PRODUCT DESCRIPTION Range of two hole, single outlet combination tap assemblies with brass bodies (various finishes), incorporating ceramic cartridge headwork and single lever operating member. Spout outlet incorporates a plastic aerator ATS3 – Without Production Surveillance.
MODEL(S) 19.974.002 Eurodisc Cosmopolitan. 19.409.xx1 Linear 23.444.xx1 Linear Where xx1 denotes finish and can be replaced with: 001 – chrome DC1 – Super Steel
SIZE: ½" BSP (F).
SCOPE: Manufacturer recommended maximum working pressure 10 Bar & maximum operating temperature 60°C. Hygienic Purposes: Non-metallic materials suitable for continuous use up to 60°C.
MARKING Grohe on operating member.
MATERIALS Non-metallic materials assessed (BS6920) to point of discharge.
BACKFLOW PROTECTION NOTES Consider balanced supplies or appropriate backflow protection at the inlets. Consideration must be made on installation to the airgap arrangement.
ADDITIONAL NOTES All water contact & exposed components satisfy opacity requirements.

Extra Notes