



SWEDISH TYPE APPROVAL 1626 WITH DECISION ON PRODUCTION CONTROL

Holder: Grohe AG

Industriepark Edelburg, 58675 Hemer, Germany

Phone: +49 237 293

Homepage: www.grohe.com

Mechanical mixers

Product description

Single-lever, 2-hole, wall mounted, basin mixers made of brass. The mixers are installed with rough-in set 23200000, Single-lever mixer 1/2", with concealed body.

The mixers are available with different coatings.

Intended use

Mixers for warm and cold tap water intended to be used for basin.

Scope

Grohe Plus, article number: 29303xx3 and 29306xx3

Approval

The products meet the requirements of Chapter 8, Section 4, of the Planning and Building Act (PBL) regarding the technical properties of Building Works in the matter of protection regarding hygiene, health and environment, provided that what is stated in this approval is followed. The products are approved according to the following section(s) of Boverkets Building Regulations (BBR):

Construction products with assessed properties,	1:4
Tap water installations,	6:62
Tap water flow,	6:623 (first sentence)
Backflow,	6:624
Design,	6:625 (paragraph 1 and 4)

Marking

Marking must be made on the product or, if there are special reasons, on the packaging or the delivery note. Marking shall indicate the following information:

Holder:	Grohe AG
Product name, and relevant article number:	Product name (article number)
Production site:	Factory ID: 0202
Year of manufacturing or other traceability to manufacturing:	yyyy-mm-dd
Information about requirements or class, if possible:	-
Boverket's registered trademark no. 241 217:	
Certification Body:	Kiwa Certification AB 
Accreditation number:	1913
Type Approval no:	TG 1626
Inspection Body:	Kiwa Certification AB

Kiwa Certification AB

Campus Gräsvik 1
SE-371 75 Karlskrona
Sweden

Tel +46 (0)455-30 56 00

Fax +46 (0)455-104 36

se.bygg@kiwa.com

www.kiwa.se



Accred. no. 1913
Certification of
Products
ISO/IEC 17065

Production sites:

Factory-IDs: 0202

Control

The manufacturers' continuing internal control is combined with surveillance inspections conducted by an accredited Inspection Body.

Inspection Body: **Kiwa Certification AB**

Inspection agreement: **148/15 revision 5**

Factory production control shall be carried out in accordance with the current instructions for control.

During inspection at the construction site, the building proprietor must verify the identity of the product by means of the marking. Furthermore, the building proprietor must ensure that the correct products are delivered and that they are installed in accordance with the manufacturer's instructions in the accompanying documents. It must also be verified that the product is accompanied by a manufacturer's declaration that certifies that production has been carried out in accordance with the documents that formed the basis for this type approval.

The validity of the Swedish Type Approval also implies that the factory production control is carried out according to the current agreement and that the holder annually fulfils the requirement in "Boverket's regulations and general recommendations for type approval", BFS 2013:6, § 5 (TYP 7), on continuing internal control. The holder shall annually, at the latest on the 15th of December, report to Kiwa Certification AB at the e-mail address se.annualreporting@kiwa.com about continuing surveillance.

Associated documents

Installation instruction: 99.1228.031 dated 02/2019 and 99.629.131 dated 11/2012 by Grohe.

The assessment basis for the approval

Mechanical test report: 190500865/001b by Kiwa Nederland B.V.

Analysis report: 416286138 by Seagull, 50723000 by HME

Assessment report: 154/2024 dated 2024-10-25

Comments

The mixers are verified according to EN 817:2008 and NKB Product Rules no. 4.

"xx" in the article number covers different coatings.

The Type approval is valid provided that the product shall neither be CE marked according to the Construction Product Regulation (EU) No 305/2011 (CPR), nor has it been suspended or withdrawn by Kiwa Certification AB.

Date of decision: 2024-10-25

Registration number: 154/2024

Valid until: 2029-10-24

Previous registration number: 1103/19


Kasem Bjelevac


Tatjana Zeidler