



SWEDISH TYPE APPROVAL 1343 WITH DECISION ON PRODUCTION CONTROL

Holder: Grohe AG

Industriepark Edelburg, 58675 Hemer, Germany

Phone: +49 2372 93 2029

E-mail: grohe@grohe.se

Homepage: www.grohe.com

Grohe mechanical mixer taps with high spout

Product description

Single-lever mixer valves with high spout, in chrome-plated brass, equipped with type approved flexible connection hoses.

Intended use

Kitchen mixer for hot and cold tap water.

Scope

Feel: 32670xx2, 32671xx2. **Bau Loop:** 31367xx0. **Bau Edge:** 31368xx0. **Eurodisc Cosmopolitan:** 32259xx3. **Eurostyle Cosmopolitan:** 31127xx2. **Eurosmart Cosmopolitan:** 32843xx2, 32843xxE. **Essence:** 30269xx0, 30505xx0, 30270xx0, 30504xx0. **Concetto:** 32661xx3. **Minta:** 31375xx0, 32488xx0, 32917xx0. **Get:** 31494xx1.

Approval

The products meet the requirements of Chapter 8, Section 4, of the "Planning and Building Act" (PBA) regarding the technical characteristics of construction works, « protection with regard to hygiene, health and the environment », depending on, that what is stated in this approval is followed. The products are approved according to the following section(s) of "Boverket's Building Regulations" (BBR):

Construction products with assessed properties	1:4
Tap water installations	6:62, 1 st sentence, 2 nd paragraph and general advice
Tap water flow	6:623, 1 st sentence
Design	6:625, 1 st and 4 th paragraph

Marking

Marking must be affixed on the product or, if there are special reasons, on the packaging or the delivery note. Marking shall indicate the following information:

Holder:

Product name, and relevant article number:

Production site:

Traceability to the production:

The registered trademark of Boverket No 241 217:

Certification Body:

Accreditation number:

Type Approval No:

Inspection Body:

Grohe AG

Product name (article number)

Applicable manufacturer or ID code
(e.g. yyyy-mm-dd or batchnumber)



Kiwa Certification AB

1913

1343

Kiwa Certification AB



CERTIFIKAT

Kiwa Certification AB

Campus Gräsvik 1
SE-371 75 Karlskrona
Sweden

Tel +46 (0)455-30 56 00

Fax +46 (0)455-104 36

se.bygg@kiwa.com

www.kiwa.se



Production site(s):

Factory ID code 0202.

Control

The manufacturers' continuing internal control is combined with surveillance inspections conducted by an accredited Inspection Body.

Inspection Body: **Kiwa Certification AB**

Inspection agreement: **148/15 revision 5**

Factory production control shall be carried out in accordance with the current instructions for control.

During inspection at the construction site, the building proprietor must verify the identity of the product by means of the marking. Furthermore, the building proprietor must ensure that the correct products are delivered and that they are installed in accordance with the manufacturer's instructions in the accompanying documents. It must also be verified that the product is accompanied by a manufacturer's declaration that certifies that production has been carried out in accordance with the documents that formed the basis for this type approval.

The validity of the Swedish Type Approval also implies that the factory production control is carried out according to the current agreement and that the holder annually fulfils the requirement in "Boverket's regulations and general recommendations for type approval", BFS 2013:6, § 5 (TYP 7), on continuing internal control. The holder shall annually, at the latest on the 15th of December, report to Kiwa Certification AB at the e-mail address se.annualreporting@kiwa.com about continuing surveillance.

Associated documents

99.1055.031, 99.1056.031, 99.0076.131, 99.0335.331, 99.1060.031, 99.1071.031, 99.1064.031, 99.1053.031, 99.1054.031, 99.0431.431, 99.0335.331, 99.0335.031, 94.432.331, 94.432.531, 94.432.631, 99.432.531, 99.432.631, 99.432.331.

The assessment basis for the approval

DTI reports 690614-22, 618899-11 and 690614-21. Kiwa report no.140102773_001 and statement 101000358_001b. TÜV Rheinland report no. 7312280-01. SINTEF report no. 201801114. Drawings and BOMs according to list dated 2025-01-24. Documentation about organic materials according to list dated 2025-01-24. Assessment report 1343-2.

Comments

The mechanical mixers are verified in accordance with EN 817:2008 and NKB 4, paragraph 3.3.2. The Type approval is valid provided that the product shall neither be CE marked according to the Construction Product Regulation (EU) No 305/2011 (CPR), nor has it been suspended or withdrawn by Kiwa Certification AB.

Date of decision: 2025-01-29

Current version: 1343-2

Valid until: 2030-01-28



Business Manager, Building & Energy
Kiwa Certification AB